

8-2-2 ABNORMAL OPERATION DISPLAY

Display type	LED 1	LED 2	LED 3	LED 4	LED 5	LED 6
Compressor1 error	◇	● (1)				
Compressor2 error	◇	● (2)				
Compressor3 error	◇	● (3)				
Discharge temprature1 error	◇	● (4)				
Discharge temprature2 error	◇	● (5)				
Discharge temprature3 error	◇	● (6)				
High-pressure error	◇	● (7)				
Low-pressure error	◇	● (8)				
Pump down error	◇	● (9)				
Discharge temperature thermistor1 error	◇		● (1)			
Discharge temperature thermistor2 error	◇		● (2)			
Discharge temperature thermistor3 error	◇		● (3)			
Heat exchange inlet thermistor1 error	◇		● (4)			
Heat exchange inlet thermistor2 error	◇		● (5)			
Heat exchange inlet thermistor3 error	◇		● (6)			
Heat exchange outlet thermistor1 error	◇		● (7)			
Heat exchange outlet thermistor2 error	◇		● (8)			
Heat exchange outlet thermistor3 error	◇		● (9)			
Suction thermistor error	◇		● (10)			
Outdoor thermistor error	◇		● (11)			
Discharge pressure sensor error	◇			● (1)		
Liquid line pressure sensor error	◇			● (2)		
Suction pressure sensor error	◇			● (3)		
Oil sensor error	◇			● (4)		
Oil recovery error	◇			● (7)		
Reverse phase blocker error	◇		●	◇	● (1)	
Reverse phase blocker error	◇				● (2)	
Power frequency faulty	◇				◇	◇
Model data error	◇	◇	◇	◇	◇	◇
EEPROM access error	◇				● (3)	
EEPROM deletion error	◇				● (4)	
Outdoor unit circuit bord error 1	◇				● (6)	
Outdoor unit circuit bord error 2	◇				● (7)	
Outdoor unit circuit bord error 2	◇	●		◇		
Communication error	◇				● (8)	
Node setting error	◇				● (9)	
Indoor unit error	◇					● (1)

Display method {
 ◇ : 0.1 sec ON / 0.1 sec OFF flashing
 ● : 0.3 sec ON / 0.3 sec OFF flashing
 () : Flashing times

Error display

